

EU type examination certificate
EU-Baumusterprüfbescheinigung

CE-0085CS0133
 Product Identification No.
 Produkt-Identnummer

| | |
|---|--|
| Field of Application <i>Anwendungsbereich</i> | EU Gas Appliances Regulation (EU/2016/426) <i>EU-Gasgeräteverordnung (EU/2016/426)</i> |
| Owner of Certificate <i>Zertifikatinhaber</i> | EMAS MAKINA SANAYI A.S. Organize Sanayi Bölgesi Mustafa Kemal Bulvari, N° 13, TR-45030 Manisa |
| Distributor <i>Vertreiber</i> | EMAS MAKINA SANAYI A.S. Organize Sanayi Bölgesi Mustafa Kemal Bulvari, N° 13, TR-45030 Manisa |
| Product Category <i>Produktart</i> | Boilers with flue systems: Condensing combi water heater (3204) |
| Product Description <i>Produktbezeichnung</i> | wall-hanging condensing combi water heater optionally also as water heater for central heating |
| Model <i>Modell</i> | Proteus Premix PPR ... |
| Countries of Destination <i>Bestimmungsländer</i> | AT, BE, BG, CH, CY, CZ, DE, DK, EE, ES, FI, FR, GB, GR, HR, HU, IE, IS, IT, LT, LU, LV, MD, MK, MT, NL, NO, PL, PT, RO, RS, SE, SI, SK, TR, UA |
| Test Reports <i>Prüfberichte</i> | supplement test: B 18/05/2697 EU from 10.05.2018 (DBI) |
| Test Basis <i>Prüfgrundlagen</i> | EU/2016/426 A III B (09.03.2016) DIN EN 15502-1 (01.10.2015) DIN EN 15502-2-1 (01.09.2017) DIN EN 13203-1 (01.12.2015) |


Date of Expiry / File No. 25.09.2027 / 18-0374-GEA
Ablaufdatum / AZ

18.06.2018 Rie A-1/2

Date, Issued by, Sheet, Head of Certification Body
 Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to DIN EN ISO/IEC 17065:2013 and notified by the government of the Federal Republic of Germany for certification of gas appliances under EU Regulation

DVGW CERT GmbH ist von der DAkkS nach DIN EN ISO/IEC 17065:2013 akkreditierte und von der Deutschen Bundesregierung benannte Stelle für die Zertifizierung von Gasgeräten gemäß EU-Verordnung EU/2016/426.




Deutsche
 Akkreditierungsstelle
 D-ZE-16028-01-01

DVGW CERT GmbH
 Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
 53123 Bonn

Tel. +49 228 91 88 - 888
 Fax +49 228 91 88 - 993

www.dvgw-cert.com
 info@dvgw-cert.com

Elektrical Data 230 V AC, 50 Hz, IPX4D
Elektrische Daten

| Appliance Categories <i>Gerätekategorien</i> | Supply Pressures <i>Versorgungsdrücke</i> | Countries of Destination <i>Bestimmungsländer</i> | Remarks <i>Bemerkungen</i> |
|--|---|---|--------------------------------------|
| I2E | 20 mbar | FR, RO | only ...V2 |
| I2E(R) | 20/25 mbar | BE | |
| I2E+ | 20/25 mbar | BE | |
| I2EK | 20/25 mbar | NL | only ...V2 |
| I2ELL | 20 mbar | DE | only ...V2 |
| I2Er | 20/25 mbar | FR | only ...V2 |
| I2H | 20 mbar | AT, BG, CH, CZ, DK, EE, ES, FI, FR, GB, GR, HR, IE, IS, IT, LT, LV, NL, NO, PT, RO, SE, SI, SK, TR | only ...V2 |
| I2H | 25 mbar | HU | only ...V2 |
| I3+ | 28-30/37 mbar | BE, IT, PT | not for ...V2 |
| I3+ | 50/67 mbar | BE, PT | not for ...V2 |
| I3B/P | 30 mbar | CY, IS, MT | not for ...V2 |
| I3B/P | 50 mbar | CY, IS, MT | not for ...V2 |
| I3P | 37 mbar | BE | not for ...V2 |
| I12E+3+ | 20/25, 28-30/37 mbar | FR | not for ...V2 |
| I12E+3+ | 20/25, 29/37 mbar | BE | not for ...V2 |
| I12E3B/P | 20, 37 mbar | PL | not for ...V2 |
| I12ELL3B/P | 20, 50 mbar | DE | not for ...V2 |
| I12ELL3P | 20, 50 mbar | DE | not for ...V2 |
| I12Er3P | 20/25, 50 mbar | FR | not for ...V2 |
| I12H3B/P | 20, 30 mbar | DK, FI, LU, SE | not for ...V2 |
| I12H3B/P | 20, 50 mbar | AT, CH, CZ, GR, LU, RO | not for ...V2 |
| I12H3B/P | 25, 50 mbar | HU | not for ...V2 |
| I12H3P | 20, 30 mbar | EE, GR, LT, LV, NO, SK | not for ...V2 |
| I12H3P | 20, 37 mbar | FR, GB, GR, HR, IE, IT, PT, SI, TR | not for ...V2 |
| I12H3P | 20, 50 mbar | CH, CZ, ES, FR, GB | not for ...V2 |
| I12L3P | 25, 50 mbar | NL | not for ...V2 |

| Type <i>Typ</i> | Technical Data <i>Technische Daten</i> | Remarks <i>Bemerkungen</i> |
|----------------------------|--|--------------------------------------|
| Proteus Premix PPR 24...; | nominal heat output: 5,6...24,5 kW | |
| Proteus Premix PPR 24...V2 | nominal heat input (Hi): 6,2...25,2 kW | |
| Proteus Premix PPR 28... | nominal heat output: 6,4...28,0 kW | |
| | nominal heat input (Hi): 7,2...28,7 kW | |
| Proteus Premix PPR 30... | nominal heat output: 6,9...30,0 kW | |
| | nominal heat input (Hi): 7,7...30,8 kW | |
| Proteus Premix PPR 35... | nominal heat output: 8,0...35,0 kW | |
| | nominal heat input (Hi): 9,0...35,9 kW | |

| Type Variation <i>Ausführungsvariante</i> | Explanations <i>Erläuterungen</i> |
|---|---|
| ...HM | for central heating and DHW-comfort |
| ...HCH | only for central heating |
| ...HST | for central heating in combination with external storage tank |
| ...V2 | alternative burners/heat exchanger |

Hints of Utilization /Remarks

Verwendungshinweise / Bemerkungen

flue types: B23, B33, C13(x), C33(x), C43(x), C53(x), C63(x), C83(x), C93x according installation manual with flue system
 ANT Kalip (approval-no.: 0432-CPD-7442)

Additional proved countries of destination, appliance categories and supply pressures:

UA (not for ...V2): I12H3P (20, 37 mbar)

MD, MK, MT, RS, UA (only ...V2): I2H (20 mbar)

In the non-EU countries the conformity approval will be accepted if the Gas Appliance Regulation EU/2016/426 is transferred into national law by this countries.

EC type examination certificate
EG-Baumusterprüfbescheinigung

CE-0085CS0133
Product Identification No.
Produkt-Identnummer

| | |
|---|--|
| Field of Application <i>Anwendungsbereich</i> | EC Efficiency Directive (92/42/EEC) <i>EG-Wirkungsgradrichtlinie (92/42/EWG)</i> |
| Owner of Certificate <i>Zertifikatinhaber</i> | EMAS MAKINA SANAYI A.S. Organize Sanayi Bölgesi Mustafa Kemal Bulvari, N° 13, TR-45030 Manisa |
| Distributor <i>Vertreiber</i> | EMAS MAKINA SANAYI A.S. Organize Sanayi Bölgesi Mustafa Kemal Bulvari, N° 13, TR-45030 Manisa |
| Product Category <i>Produktart</i> | Boilers with flue systems: Condensing combi water heater (3204) |
| Product Description <i>Produktbezeichnung</i> | wall-hanging condensing combi water heater optionally also as water heater for central heating |
| Model <i>Modell</i> | Proteus Premix PPR ... |
| Type of Boiler <i>Heizkesseltyp</i> | condensing boiler |
| Test Reports <i>Prüfberichte</i> | supplement test: B 18/05/2697 EU from 10.05.2018 (DBI) |
| Test Basis <i>Prüfgrundlagen</i> | EU/92/42 (21.05.1992) |
| File Number <i>Aktenzeichen</i> | 18-0374-GWA |


70028-04-A-DE

18.06.2018 Rie A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to DIN EN ISO/IEC 17065:2013 and notified by the government of the Federal Republic of Germany for certification of heating boilers under EC Directive 92/42/EC.

DVGW CERT GmbH ist von der DAkkS nach DIN EN ISO/IEC 17065:2013 akkreditierte und von der Deutschen Bundesregierung benannte Stelle für die Zertifizierung von Heizkesseln nach der Richtlinie 92/42/EWG.




DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

| Type Typ | Technical Data Technische Daten | Energy Labelling Energieeffizienzkennzeichnung |
|---|--|---|
| Proteus Premix PPR 24...; Proteus Premix PPR 24...V2 | nominal heat output: 5,6...24,5 kW nominal heat input (Hi): 6,2...25,2 kW | |
| Proteus Premix PPR 28... | nominal heat output: 6,4...28,0 kW nominal heat input (Hi): 7,2...28,7 kW | |
| Proteus Premix PPR 30... | nominal heat output: 6,9...30,0 kW nominal heat input (Hi): 7,7...30,8 kW | |
| Proteus Premix PPR 35... | nominal heat output: 8,0...35,0 kW nominal heat input (Hi): 9,0...35,9 kW | |